

Test Report

I. Information of Customer

- 1) Place information : Korea
- 2) Type of Customer : Bank
- 3) Name of Customer : JB Bank
- 4) Capacity of load

II. Intallation Information

- 1) Date of Installation : 2008.2.22
- 2) Model of ULTRA : U-303

III. Test Result

- 1) Before Installation
 - a. Duration of collecting information : 2008.2.9~2008.2.21
 - b. Power consumption : 13186.07 KWH
 - c. Average dialy power consumption : week-11714.84 weekend-1471.23
- 2) After installation
 - a. Duration of collecting information : 2008.2.23~2008.3.6
 - b. Power consumption : 11222.86 KWH
 - c. Average dialy power consumption : week-10162.91 weekend-1059.95

V. Result

Power Saving Rate : **14.89%**

