


■ Test report of Carrefour in Columbia



1. Place :

Avda. 15 No. 106-57 Piso 4°. Santafé de Bogotá, D.C.

2. Date : 2008.7.28


3. Model : U-1000 2pcs

4. Compared power consumption of July with Aug & Sep during closed hour 22:00 ~ 07:00  
 (Because, there always difference of circumstance such as number of customer. And there are the same load during opened hours)

5. Power saving rate

2008	22:00~07:00	22:00~07:00
July	120,933.94	<b>Rate saving</b>
Aug	111,833.42	<b>-7.53%</b>
Sep	111,580.42	<b>-7.73%</b>

6. Graph of power saving rate



7. picture of plac

